

CARNEYS POINT TOWNSHIP SEWERAGE AUTHORITY

RESOLUTION 2017-34

**DECLARING AN EMERGENCY AND AUTHORIZING REPAIR
SANITARY SEWER REPAIR AT THE
ROUTE 295 PUMP STATION GRAVITY MAIN**

WHEREAS, on or about May 31, 2017 the Authority Engineer, Sickels & Associates, was notified that a sink hole was occurring over the gravity sewer main upstream from the Route 295 Pump Station and it is believed that a portion of the pipe has collapsed; and

WHEREAS, Authority personnel determined that the sewer main integrity is compromised; and there is the likelihood, due to the current condition of the sink hole and the underlying sanitary sewer main, of a full blockage of the sewer main; and it was agreed that the proper course of action is to immediately replace the section of the sewer main due to the potential threat to the health, safety and welfare of the general public.

WHEREAS, due to the emergency nature of this project, the Carneys Point Township Sewerage Authority's engineer solicited 5 contractors and obtained quotes from two. Pioneer Pipe Contractors, Inc., provided the lowest quote for this emergency repair with an estimate of \$97,600.00;

NOW BE IT THEREFORE RESOLVED, the Carneys Point Township Sewerage Authority does hereby declare this event an emergency condition and authorizes the services of Pioneer Pipe Contractors, Inc., to make the repair at an estimated cost of \$97,600.00.


Joseph F. Racite, Authority Secretary

Date of Adoption: June 20, 2017

Committee	Moved	Seconded	Y	N	Abstain	Absent
Dr. Racite	X		X			
Mr. Pelura			X			
Mr. Gatani		X	X			
Mr. Newton			X			
Mr. Rullo			X			