

**CARNEYS POINT TOWNSHIP SEWERAGE AUTHORITY**

**RESOLUTION 2020-30**

**DECLARING AN EMERGENCY AND AUTHORIZING THE  
REPAIRS FOR RBCs 1B, 2A, AND 2C AT THE  
CPTSA WASTEWATER TREATMENT PLANT**

WHEREAS, on July 20, 2020 the operations staff notified the Engineer regarding failure of the drive-side stub shaft on RBC 2A at the CPTSA Wastewater Treatment Plant; and

WHEREAS, RBCs 1B and 2C were already out of service due to previous failures of the drive-side shafts; and

WHEREAS, due to the emergency nature, the Authority Engineer contacted an RBC specialist company, Mountain Machine Works, to review the issues and provide a quote to fix the units and return them to service; and

WHEREAS, the Authority Engineer has reviewed the RBC failures and the proposed repair work; and

WHEREAS, the Authority Engineer in coordination with the Authority operations staff will verify the work, review the invoices, and provide the Authority with a recommendation for payment; and

WHEREAS, due to the potential threat to public health and the environment, as determined by the Authority Engineer and licensed operations staff, the proper course of action is to repair RBCs 1B, 2A, and 2C immediately, without the benefit of the Public Bid process;

NOW BE IT THEREFORE RESOLVED, the Carneys Point Township Sewerage Authority does hereby declare this event an emergency and authorizes the services of Mountain Machine Works to complete the repair.



Authority Secretary, Chairman

Date of Adoption: August 18, 2020

Committee	Moved	Seconded	Y	N	Abstain	Absent
Rullo	✓		✓			
Newton			✓			
Racite			✓			
Pelura			✓			
Brown		✓	✓			