

CARNEYS POINT TOWNSHIP SEWERAGE AUTHORITY

RESOLUTION 2024-73

DECLARING AN EMERGENCY AND AUTHORIZING A REPAIR TO THE ROTATING BIOLOGICAL CONTACTOR

WHEREAS, on or about November 17, 2024 the operations staff made arrangements for an emergency repair to the low-density Rotating Biological Contactor (“RBC”) which experienced shaft failure causing the RBC to be taken out of service; and

WHEREAS, due to the emergency nature of this failure, the Carneys Point Township Sewerage Authority (“CPTSA”) hired Darlington Equipment to perform the repair to the RBC; and

WHEREAS, Darlington Equipment is the only contractor qualified to replace the RBC shaft which there qualified this as an Extraordinary Unspecifiable Expense; and


WHEREAS, the CPTSA Superintendent reviewed the repair work; and

WHEREAS, the CPTSA Superintendent in coordination with the CPTSA operations staff verified the work and reviewed the invoices from Darlington Equipment; and

WHEREAS, due to the potential threat to the general health and safety associated with the RBC, the proper course of action was to repair the RBC immediately, without the benefit of the process as prescribed under Local Public Contracts Law;

NOW BE IT THEREFORE RESOLVED, the Carneys Point Township Sewerage Authority does hereby declare this event an emergency and authorizes the services and payment to Darlington Equipment in the amount of \$44,990.00.

AND BE IT FURTHER RESOLVED, that this work constituted an Extraordinary Unspecifiable Expense.



Kenneth Brown, Chairman

Date of Adoption: December 17, 2024

Committee	Moved	Seconded	Y	N	Abstain	Absent
Mr. Bomba	✓		✓			
Mr. Basile			✓			
Mr. Brown			✓			
Mr. Newton			✓			
Dr. Racite		✓	✓			